

## Part 3 Environmental Protection

### NRB 3-7 Refrigerants

Actual Assessment Submission

Site Verification Submission

Criteria	Credit Available	Credit Claimed
(a) Refrigerants with 0 ozone depleting potential (ODP) or with <100 global warming potential (GWP)	1	
(b) Use of refrigerant leak detection system	1	

#### Strategies:

**Documentary Evidences:**

*Order of documents to be submitted accordingly and clearly labeled.*

Actual Assessment	Submitter	Assessor
<i>3-7 (a) Use of refrigerant</i>		
1. Extracts of the tender specification showing the requirement for all refrigerants to have ODP of zero <b>OR</b> GWP of less than 100.	<input type="checkbox"/>	<input type="checkbox"/>
2. Technical product information highlighted refrigerants to have ODP of zero <b>OR</b> GWP of less than 100.	<input type="checkbox"/>	<input type="checkbox"/>
<i>3-7 (b) Use of refrigerant leak detection system</i>		
1. Extracts of the tender specification showing the requirement to incorporate a refrigerant leak detection system.	<input type="checkbox"/>	<input type="checkbox"/>
2. Schematic drawing showing the location of the refrigerant leak detection system at critical areas of plant room containing chillers and others equipment with refrigerants.	<input type="checkbox"/>	<input type="checkbox"/>
3. Product technical information of the system.	<input type="checkbox"/>	<input type="checkbox"/>

Site Verification	Submitter	Assessor
<i>3-7 (a) Use of refrigerant</i>		
1. Technical product information of refrigerant used with its purchase and delivery order.	<input type="checkbox"/>	<input type="checkbox"/>
2. Describe any deviations or changes to AA submission.	<input type="checkbox"/>	<input type="checkbox"/>
<i>3-7 (b) Use of refrigerant leak detection system</i>		
1. Technical specification of the installed refrigerant leak detection system and its purchase and delivery order.	<input type="checkbox"/>	<input type="checkbox"/>
2. As-built schematic drawing showing the location of the refrigerant leak detection system at critical areas of plant room containing chillers and others equipment with refrigerants.	<input type="checkbox"/>	<input type="checkbox"/>
3. Photographic evidences.	<input type="checkbox"/>	<input type="checkbox"/>
4. Describe any deviations or changes to AA submission.	<input type="checkbox"/>	<input type="checkbox"/>